

# TEST CONFIRMATION

## on Hydrogen Suitability

100 Vol.-% in Natural Gas

The DVGW Test Laboratory Energy of DBI - Gastechnologisches Institut gGmbH  
Freiberg confirms the successful testing of

Press fittings made of copper and copper alloys for copper pipes  
“SANHA Press-Gas”

according to the test basis

DBI-GTI 113:2021-11

Tests according „H2ready“ for manually operated ball valves and closed bottom taper plug valves  
for gas installations for buildings

The results of the test are documented in the following test report.

B 22/11/3963 | 30.11.2022

Based on this test mark confirmation, the applicant

SANHA GmbH & Co. KG, Hauptstraße 76, 01909 Goßharthau-Schmiedefeld

is authorized to apply the quality mark H2ready for the above mentioned products in accordance with the  
statutes. The test confirmation is valid until 30.11.2025.



Dipl.-Ing. Ronald Aßmann  
Leiter Prüflaboratorium

Freiberg, den 01.12.2022

DBI - Gastechnologisches Institut gGmbH Freiberg | DVGW-Prüflaboratorium Energie  
Halsbrücker Straße 34 | D-09599 Freiberg, Germany | pruefstelle@dbi-gruppe.de

This test confirmation is the English language version. In case of doubt the wording according to the German language version of the test confirmation is valid.

This test confirmation attests to the compliance of the products mentioned with the technical requirements in the test specifications mentioned above. It does not confirm standard conformity of the tested products. The H2ready warranty mark is only valid in conjunction with the above-mentioned test report(s). If conditions are specified in the test reports associated with the warranty mark, the right to use the warranty mark does not commence until they have been implemented.